



2007 Annual Drinking Water Quality Report

For

Town of Alpine

PWS WY5600156C

PO Box 3070

Alpine WY 83128

(307) 654-7754

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two ground water wells drawn from the Madison Aquifer.

If you have any questions about this report or concerning your water utility, please contact **Val Jensen, Town Clerk** at (307) 654-7754. We want our valued customers to be informed about their water utility. If you want to learn more, please call for the date and time of the next scheduled meeting.

Town of Alpine routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2007. As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:


Non-Detects (ND) - laboratory analysis indicates that the laboratory does not detect the constituent.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.


Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.



Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants						
Total Coliform Bacteria	N	Negative	N/A	0	Presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
Radioactive Contaminants						
Alpha emitters (January 2007) (April 2007)	N	ND 2.3	pCi/l	0	15	Erosion of natural deposits
Inorganic Contaminants						
Barium (March 2006)	N	0.2	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper (Source) (March 2006)	N	ND	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Copper (Pb&Cu Rule/Tap Monitoring) (September 2007)	N	0.12	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride (March 2006)	N	0.4	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead (Pb&Cu Rule/Tap Monitoring) (September 2007)	N	4	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (as Nitrogen) (March 2007)	N	0.2	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (March 2006)	N	3.5	ppm	None	None	Natural occurring

MAR 27 2008
By 

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Volatile Organic Contaminants						
THHM [Total trihalomethanes] (March 2006)	N	0.59	ppb	0	100	By-product of drinking water chlorination
Disinfectants and Disinfection Byproducts						
THHM (Total trihalomethanes) (March 2006)	N	ND	ppb	N/A	80	By-product of drinking water chlorination
HAA5 (Haloacetic Acids) (March 2006)	N	ND	ppb	N/A	60	By-product of drinking water chlorination

What does this mean?

As you can see by the table, our system has no Maximum Contaminant Level violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. Lead in drinking water is rarely the sole cause of lead poisoning, but it can add to a person's total lead exposure. All potential sources of lead in the household should be identified and removed, replaced or reduced. The EPA has determined that your water IS SAFE at these levels.

We test for a total of 76 contaminants. Those of which were undetected, are not included in the table. A list is available upon request.

Some of our data in the tables are more than one year old, since certain chemical contaminants are monitored less than once a year. Our sampling frequency complies with EPA drinking water regulations.


The sources of drinking water include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it can dissolve naturally occurring minerals and, in some cases, radioactive materials. The water can also pick up substances such as:

- 1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural operations and wildlife.
- 2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic waste water discharges, oil and gas production, mining or farming.
- 3) Pesticides and Herbicides, which may come from agriculture, urban storm water runoff, and residential uses.
- 4) Organic chemical contaminants, which can come from industrial processes, gas stations, urban storm water runoff and septic systems.
- 5) Radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities.

In order to insure that tap water is safe to drink, EPA establishes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration establishes limits for contaminants in bottled water.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink a half gallon of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ



transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791) or EPA (800-227-8917).

We at the Town of Alpine work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

