

MONTE VISTA SKATEBOARD PARK RFP
QUESTION AND ANSWER BOARD

February 1, 2012

Q: The RFP ask for Pre-Cast experience in the firm qualifications section. I assume Poured-In-Place experience is acceptable/interchangeable, as it is the preferred method for Skatepark construction.

A: Poured in place experience is acceptable/interchangeable. The city will accept RFP's utilizing poured in place technology that meets industry construction standards for skate parks.

Q: Can you give more detail of the scope regarding Storm Water Management. Are you looking for basic drainage/outlets or wanting an in-depth storm water management plan.

A: Proposals must include a storm water management plan describing how water will be drained from the surface of the skate park including any bowls proposed as part of the project scope. It is not anticipated storm water will be tied to the city's storm water system but disposed of on site.